

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0085:190 Page 1 of 1

CATEGORY: Control Units (Non High Rise)

LISTEE: ADT Security Services, Inc., 4128 North Freeway Blvd., Sacramento, CA 95834-1219
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942*

DESIGN: Model 472462 combination fire and burglary alarm control unit. Automatic, manual, local, remote station (PPU), central station (PPU), proprietary station (PPU), waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

472462	Control unit
SAFOC200	Sub-assembly Circuit Board
COM-UL	Enclosure
443216 or 472404	Transformer

RATING: 120 VAC, 18 VAC, Transformer and 12 VDC battery back-up

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a combination fire and burglary alarm control units for use with the separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

XLf: 7165-0078:197

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager